





Chaussée de Vilvorde, 156
Vilvoordsesteenweg 156
B-1120 Bruxelles/Brussel
Tel.: 32 (0)2 264 03 60
Fax: 32 (0)2 268 89 58
http://www.apragaz.com
info@apragaz.com



NOTIFIED BODY EC TYPE EXAMINATION CERTIFICATE						Certificate N°	
In accordance with module B of the Marine Equipment Directive 96/98/EC as amended						12/PL/2757-2-REV 1	
Manufacturer		Name					
		KZWM Ogniochron S.A.					
		Address					
		34-120 Andrychow Krakowska 83C, POLAND					
Concerned Equipment : Portable Fire Extinguishers							
Mark	Type	Nominal charge	EN3.7 test report n°	Fire Classes	Operation temperature range	Working Pressure at T° max	Test Pressure (PT)
KZWM OGNIОCHRON S.A.	GP-1x ABC	1 kg ABC Powder Type "FUREX ABC Standard 20%"	EN 10706	5A – 21B	-30°C +60°C	13 bar	25 bar
KZWM OGNIОCHRON S.A.	GP-2x ABC	2 kg ABC Powder Type "FUREX ABC Plus 40%"	EN 10707	13A – 89B	-30°C +60°C	13 bar	25 bar
KZWM OGNIОCHRON S.A.	GP-1z BC/AP	1 kg BC Powder Type "SOLVAY BI-EX"	EN 11468	34B C	-30°C +60°C	13 bar	25 bar
KZWM OGNIОCHRON S.A.	GP-6x ABC/MP	6 kg ABC Powder Type "CALDIC Furex S"	2013-F-0209/OG 11	43A 233B	-30°C +60°C	13 bar	25 bar
KZWM OGNIОCHRON S.A.	GS-5x B/MP	5 kg CO2	2014056 8/ OG16	89B	-30°C +60°C	216,1 bar	315 bar
<p>The manufacturer is allowed to affix the marine CE mark  (followed by our n° 0029 and the year of manufacturing) to approved equipment in the conditions described in article 11 of the Directive , only if the requirements stated in module D are fully complied with.</p> <p style="text-align: center;">The approval is valid until 26/03/2017</p>							
<p>APRAGAZ, acting within the scope of its notification for the Directive 96/98/EC, certifies that the types of equipment defined here above are conform to the requirements of the EN 3 in force and to the Marine Equipment Directive 96/98 as amended, on base of the documentation and samples supplied for review and approbation.</p>							
Date : 15/06/2015		Name : Ch. Leplat		Position General Manager			
Notified body identification number :		0029		Signature 			
Notified body stamp :		<p>APRAGAZ Belgium Inspecting Authority</p>					
Notified body reference :		1111/P14007/001					