

MPA Dresden GmbH · Fuchsmühlenweg 6F · D-09599 Freiberg

KZWM Ogniochron S.A.  
ul. Krakowska 83c  
34-120 Andrychów  
Poland

Date, April 29<sup>th</sup>, 2014  
Official: Mr. Bauer  
Phone: +49-(0)3731- 2 03 93 164  
Telefax: +49-(0)3731- 2 03 93 110  
e-mail: t.bauer@mpa-dresden.de  
project number: 20140580  
(Please state in case reply.)

**Your order no. 184/04/14 dated on 10<sup>th</sup> April 2014**  
Fire performance tests following to EN 3-7<sup>1)</sup>


Dear Sirs or Madams,

We herewith confirm the following stated test results which have been obtained in the presence of you in our test laboratory on 15<sup>th</sup> April, 2014.

Extinguisher model	Propellant, nozzle	Extinguishing agent	Filling rate	Fire rating	Extinguishing time (min:s)	Passed (yes/no)
UGD-1x ABF <sup>2)</sup>	10 bar N <sub>2</sub> , Ø 1,2 mm	FUREX CASA (SP 41/05)	700 ml	3 A 21 B 5 F	3:30 0:19 0:46	Yes Yes Yes
UGD-1x AF <sup>2)</sup>	10 bar N <sub>2</sub> , Ø 1,2 mm	FUREX CASA Bio (SP 01/12)	700 ml	3 A 5 F	2:55 0:37	Yes Yes

If you have any further questions please don't hesitate to contact us.

Yours sincerely



Jürgen Dittrich  
Laboratory Manager

<sup>1)</sup> Deviating nominal charge from table 4, 6 and II of EN 3-7

<sup>2)</sup> Brimful capacity of cylinder 1,1 dm<sup>3</sup>